



Charlie Crist
Governor


Ana M. Viamonte Ros, MD., M.P.H.
Secretary of Health


INTEROFFICE MEMORANDUM

**INFORMATION
HSES 07-006**

DATE: April 2, 2007

TO: County Health Department Directors/Administrators
ATTN: Environmental Health and Engineering Directors

THROUGH: Lisa Conti, D.V.M., M.P.H., Dipl. ACVPM, CEHP
Director, Division of Environmental Health 

FROM: 
Gerald Briggs, Chief,
Bureau of Onsite Sewage Programs

SUBJECT: ANSI/NSF Standard 40, Class I, Aerobic Treatment Unit (new listing)

INFORMATION ONLY

Ecological Tanks, Inc. with the Aqua Aire (500 and 800 gallon) Wastewater Treatment System Aerobic Treatment Unit (ATU) has been certified as meeting all of the requirements of ANSI/NSF Standard 40 - Residential Wastewater Treatment Systems for Class I classification. Please add it to the listing of ATUs acceptable for use in the State of Florida.

Attached, you will find a PDF file of the performance testing and evaluation certification report conducted by NSF International.

The following septic tanks manufactured by Sebring Septic Tank and Precast Co. have been approved for use in the State of Florida with the above listed aerobic treatment units.

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	EFFECTIVE GALLONS	APPROVAL DATE
28-O15-AA1-C3	C-3	2.50	52.5	800	06/30/06
28-O15-AA2-C3	C-3	2.50	54	500	10/05/06

Please direct any questions to Kim Duffek at (850) 245-4070 or SC 205-4070.

Attachment
cc: Ecological Tanks, Inc.

